

Installation of Resilient Furring Channel to Steel or Wood Framing Members:

Note: These guidelines are for ClarkDietrich Building System's single leg RC Deluxe and RC-1 Pro, and double leg RC-2 Pro. Details of construction for a specific assembly to achieve the required fire or sound or acoustic rating shall be obtained from fire test reports, sound, or acoustic tests, engineering evaluations, or listings from recognized sound or acoustic laboratories.

Install resilient furring channels at right angles (perpendicular) to the framing members. The resilient furring channel shall be positioned with the slotted hole(s) directly over the framing member. The resilient furring channel shall be attached to the framing member using the screw hole provided in the mounting flange. If no screw hole is provided or located at the framing member, attach through the mounting flange.

No more than two layers of up to 5/8 in. (16mm) gypsum panel products should be installed to resilient furring channel.

Resilient furring channels should not be spaced greater than 24 in. (610 mm) on-center when installed on wall framing members. For ceiling framing members spaced 24 in. (610 mm) on-center install resilient furring channels at 16 in. on-center maximum. For ceiling framing members spaced 16 in. (406 mm) on-center install resilient furring channels at 24 in. (610 mm) on-center maximum.

In the case of wall framing members, resilient furring channels should be installed with the mounting flange of the resilient furring channel down, except at the floor or starter row where the mounting flange may be installed with the flange up to accommodate fastening to the framing members. In the case of two-legged resilient furring channel attach only the lower mounting flange to the wall-framing members except as noted.

Note 1: By keeping the mounting flange down the weight of the gypsum panel products will pull the resilient channel away from the stud improving the sound rating.

Note 2: Two-legged resilient furring channels may be attached to the wall and ceiling framing members using both legs. Alternately attach the legs of the resilient furring channel to the framing members. This method of attachment may reduce the sound rating performance of the assembly. Verify acceptability with the approving authority prior to installation.

For walls, install the first (lowest) row of resilient furring channel no more than 2 in. (51 mm) off of the floor and the last (highest) row of resilient furring channel not more than 6 in. (152 mm) from the ceiling. For ceilings, the first row and last row of resilient furring channel shall be located not more than 6 in. (152 mm) from the adjacent wall. (Measurements are to the center of the face of the resilient furring channel.)

Attach resilient furring channel to framing members with screws only. For steel framing, Type-S x 3/8 in. (9.5 mm) pan head framing screws may be used. For wood framing members, Type-W or Type-S screws (minimum 1 ¼ in. (32 mm) long) may be used. It is not recommended that nails be used. Install the screws in the holes provided in the mounting flange (whenever possible).

Splicing of resilient furring channel members shall be done by "nesting" the ends of the resilient furring channel members directly over the framing member and screwing through the mounting flanges into the framing member. (An acceptable alternative would be to butt the resilient furring channel members over the framing member leaving a minimum 1/16 in. (1.6mm) gap between resilient furring channels.)

Gypsum panel products shall be attached to the resilient furring channel using a screw length to ensure that the screw point does not make contact with the framing member. (This will minimize the potential of the screws hitting the wall studs and "short-circuiting" the sound resistance effectiveness of the resilient furring channels.)